

TAMILNADU FIRE - RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

LICENSE No. :10 / 2025

R.C.No. :64 / V /RDH / 2025

Date: 23.06.2025

Sub : Fire and Rescue Service - Fire and Rescue Station Redhills – Issuing of

No Objection Certificate – Functioning the School

Ref : 1.G.O/M.s 122Dt:14-09-2004/Dept.ofSchoolEducation,TamilNadu.

2.G.O/M.s123Dt:14-09-2004/Dept.of SchoolEducation,TamilNadu.

3.Application Received from Correspondent of ALPHA INTERNATIONAL SCHOOL Dated on 07.02.2025

Certified that the **ALPHA INTERNATIONAL SCHOOL at No. 48, 49, Sivanthi Adhithanar Nagar, Puzhal, Chennai -600066**, Tamil Nadu, comprises of 1 Block and ground floor, G+1 and G+2 (upper floors) is owned by **ALPHA INTERNATIONAL SCHOOL** have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified by the officers concerned of Fire Service on 23.06.2025 in the presence of **Mr. Jerold Finny, Manager, ALPHA INTERNATIONAL SCHOOL at No.48, 49, Sivanthi Adhithanar Nagar, Puzhal, Chennai -600066**, Tamil Nadu and that the building/premises is fit for occupancy upto class XII with effect from 24.06.2025 for period of **01** Year in accordance with rules.

The above is valid for a period of 01 Year.

CONDITIONS


1. Fire safety systems should be maintained in Good working condition.
2. Mock drill to be conducted periodically with the help of local fire brigade.
3. Any erection of permanent or temporary structure should be intimated to this department.
4. Further to limit the occupant load and to ensure better fire and lifesafety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per sq.Meter as per national Building code-2005.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As per Para 6.3 of the BIS standards IS14435:1997 if the classroom shave only one entrance, the capacity of the classrooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipment's.
 - e. Mockdrill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Sub-Urban District at Ambattur.

Official Seal



To

**ALPHA INTERNATIONAL SCHOOL,
NO.48,49, SIVANTHI ATHITHANAR NAGAR,
PUZHAL, CHENNAI – 600 066.**


**STATION OFFICER
FIRE & RESCUE STATION,
REDHILLS, CHENNAI-600052.**